



Office of the District Fire Officer
Karnataka State Fire & Emergency Services
VIJAYAPUR Fire Station, VIJAYAPUR-586101
Telephone:08352-270160



C.NO.259/FSCR/DFO/VIJAYAPUR/2026

Date- 02/06/2026

To,

The Chairman
Smt Narasamma Gotyal (Atharga)
Shikshan Samsthe (R) Hanchanal P.H
Tq- Tikota Dist- Vijayapura

Sub : Issue of 'Fire Safety Compliance Report' to Roopa International Pre-Primary School, Roopa International English Medium Primary & High School, Roopa International CBSE School, Roopadevi Science P.U. College, Situated at Sy No.105/D/2, 105/D/3, 105/D/4, Opp. To Sheshanag Hotel , Solaphur By-pass , Hanchanal P.H Tq- Tikota Dist- Vijayapura.

Ref: 1. NO:GBC(2)2100/2025 Date:03/02/2026

2. Applicant Request Letter Date:22/05/2026

3. C.No.206/ADV/CFO/HBL/2021 Date- 24/09/2021

><<>*@*<<>

With reference to the subject above cited, the premises of Roopa International Pre-Primary School, Roopa International English Medium Primary & High School, Roopa International CBSE School, Roopadevi Science P.U. College, Situated at Sy No.105/D/2, 105/D/3, 105/D/4, Opp. To Sheshanag Hotel , Solaphur By-pass ,Hanchanal P.H Tq- Tikota Dist- Vijayapura was inspected by The District Fire Officer, Vijayapur on 27/05/2026 with respect to Fire prevention, Fire fighting and Evacuation measures complied in the above premises and the details as under.

ANNEXURE-1

(Up to 21.00 mtrs. In height)

"GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the building / premises :-

01.	Name and Address of the Applicant.	:	The Chairman Smt Narasamma Gotyal (Atharga) Shikshan Samsthe (R) Hanchanal P.H Tq- Tikota Dist- Vijayapura
02.	Name and Address of the premises.	:	1. Roopa International Pre-Primary School 2. Roopa International English Medium Primary & High School 3. Roopa International CBSE School 4. Roopadevi Science P.U. College Situated at Sy No.105/D/2, 105/D/3, 105/D/4, Opp. To Sheshanag Hotel ,Solaphur By-pass Hanchanal P.H Tq- Tikota Dist- Vijayapura
03.	Name and address of the building owner	:	The Chairman Smt Narasamma Gotyal (Atharga) Shikshan Samsthe (R) Hanchanal P.H Tq- Tikota Dist- Vijayapura
04.	Number of buildings	:	01 Building.
05.	Number of floors	:	G+2 floors
07.	<u>Floor wise details of occupancy:-</u>		
	Ground floor	:	Class Room-07, Principal Room, Office Rom-02, Record Room, Waiting hall, Staff Room,

	1 st Floor	:	Class Room-07, Computer Room, Biology Lab, Physics lab,
	2 nd Floor	:	Class Room-07, Chemistry Room, Auditorium Room, Store Room.
08.	Height of the building	:	12.20 mtr
09.	Site area	:	5199.00 Sq mtr
10.	Built-up area of each floor:-		
	Ground Floor	:	1290.09 Sq.mtr
	1 st Floor	:	1361.28 Sq.mtr
	2 nd Floor	:	1284.43 Sq.mtr
11.	Total built-up area	:	3935.80 Sq.mtr
12.	Surrounding properties:-		
	East	:	Road
	West	:	Open Land
	North	:	Garden
	South	:	Hostel Building
13.	Set-back area available around the building :-		
	East	:	02.00 mtr
	West	:	02.00 mtr
	North	:	10.00 mtr
	South	:	02.00 mtr

B. On inspection of this Institutional premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																		
01.	Accessibility to the premises	The premises is accessible from 09.00 mtr wide road on the Eastern side.	Adequate																		
02	No. of entrances	02 nos in the Southern side.	-																		
03.	Width of entry / exit	03.98 mtr & 03.30 mtr	-																		
04.	Diesel generators.	Provided 15KV generator & is connected to all the lighting & emergency provisions in the building.	Complied.																		
05.	No. of staircases available	<table><tr><td>Nos. of staircases</td><td>:</td><td>03 no</td></tr><tr><td>Width of staircases</td><td>:</td><td>01.50 mtr each</td></tr><tr><td>Width of treads</td><td>:</td><td>0.30 mtr each</td></tr><tr><td>Height of risers</td><td>:</td><td>0.15 mtr each</td></tr><tr><td>Nos. of riser per flight</td><td>:</td><td>12 nos</td></tr><tr><td>Height of handrails</td><td>:</td><td>0.90 mtr</td></tr></table>	Nos. of staircases	:	03 no	Width of staircases	:	01.50 mtr each	Width of treads	:	0.30 mtr each	Height of risers	:	0.15 mtr each	Nos. of riser per flight	:	12 nos	Height of handrails	:	0.90 mtr	The staircase must be free from Obstruction all the time.
Nos. of staircases	:	03 no																			
Width of staircases	:	01.50 mtr each																			
Width of treads	:	0.30 mtr each																			
Height of risers	:	0.15 mtr each																			
Nos. of riser per flight	:	12 nos																			
Height of handrails	:	0.90 mtr																			
06.	Fire extinguisher	Provided 15 no's of ABC Type Fire extinguishers Each 06.00 Kgs Capacity, & 03 no's of CO2 Type Fire extinguishers Each 04.50 Kgs Capacity in the building.	Complied.																		
07.	Hose reel hose system	03 no's of Hose reel hose of min 19 mm size and of 30 mtrs length has been provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size. The hose reel hose has been connected at each landing.	Complied.																		
08.	Over head tank	The system has been connected to an over head tank of 5000 ltrs capacity & is connected to 450 lpm pump.	Complied.																		
09.	Booster pump	The system has been connected to an booster pump of 450 LPM.	Complied.																		
10.	Escape routes	Escape route has been marked with luminous light/paint in each floor of the building directing towards exists and emergency exists.	Complied.																		

11.	Fire order	Fire safety indicating the details of actions to be taken in case of emergency has been displayed in the building with the telephone numbers of our Vijayapura Fire Station 08352-270160,112 and 101 numbers & telephone numbers of nearest Ambulance Service.	Complied.
12.	No Smoking board	COPTA Sec-4 direction of No Smoking area , smoking here is an offence board has been written in English & Kannada both languages & is prominently displayed inside the entry/exit of the each floor.	Complied.
13.	Fire Siren	A Fire Siren has been installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.	Complied.
14.	Nominate One Fire Nodal Officer	Shri Praveen Hanawad has been nominated as the Fire Nodal Officer .	Complied.
15.	Fire fighting training	02 persons have undergone training in basic fire fighting course from 05/05/2026 to 06/05/2026 in the premises of The District Fire Office Vijayapura. (Copies Enclosed) 1. Shri Praveen Hanawad 2. Shri Raghavendra B Hosamani	At least 40% of employees shall be trained in basic fire fighting course at our R.A.Mundkur Fire and Emergency Services Training Academy, Bannerghatta Road, Bangalore-29 or at The Regional Fire Office Hubli or at The District Fire Office Vijayapura.
16.	Fire Precautionary Measures A:- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sum panel premises. B:- Accumulation of combustibile waste in and around the premises should be avoided. C:- Exits shall be always kept clear without any obstruction. D:- Petroleum gas should not be stored in the building. E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction. F:- During the class hours the class room door shall not be locked from inside to out side. G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordination with the fire services department.		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing '**Fire Safety Compliance Report**' to Roopa International Pre-Primary School, Roopa International English Medium Primary & High School, Roopa International CBSE School, Roopadevi Science P.U. College, Situated at Sy No.105/D/2, 105/D/3, 105/D/4, Opp. To Sheshanag Hotel , Solapur By-pass , Hanchanal P.H Tq-Tikota, Dist- Vijayapura with the condition of maintaining the fire fighting installations in the good working condition periodically.

This "**Fire Safety Compliance Report**" is valid for only one year from the date of issue.

Yours Faithfully

B. S. S.
02/06/26
DISTRICT FIRE OFFICER
VIJAYAPUR-586108